



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

JOK1479

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: SL BOCES - NW Tech - Daycare

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 11/06/2020
 Reported: 12/07/2020

Analytical Testing Parameters

Client Sample ID:	3	Collected By:	LS-Client
Sample Matrix:	Drinking Water	Collection Date:	10/27/2020 8:18
Lab Sample ID:	JOK1479-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/30/20 0944	11/30/20 1334	LLW

Client Sample ID:	2	Collected By:	LS-Client
Sample Matrix:	Drinking Water	Collection Date:	10/27/2020 8:17
Lab Sample ID:	JOK1479-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		11/30/20 0944	11/30/20 1340	LLW

Client Sample ID:	4	Collected By:	LS-Client
Sample Matrix:	Drinking Water	Collection Date:	10/27/2020 8:19
Lab Sample ID:	JOK1479-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/30/20 0944	11/30/20 1341	LLW

Client Sample ID:	6	Collected By:	LS-Client
Sample Matrix:	Drinking Water	Collection Date:	10/27/2020 8:21
Lab Sample ID:	JOK1479-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/30/20 0944	11/30/20 1343	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1479

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: LS-Client
Lab Sample ID: J0K1479-05		Collection Date: 10/27/2020 8:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		11/30/20 0944	11/30/20 1349	LLW

Client Sample ID: 7	Sample Matrix: Drinking Water	Collected By: LS-Client
Lab Sample ID: J0K1479-06		Collection Date: 10/27/2020 8:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		11/30/20 0944	11/30/20 1351	LLW

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: LS-Client
Lab Sample ID: J0K1479-07		Collection Date: 10/27/2020 8:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.015 AL	0.0010	mg/L		11/30/20 0944	11/30/20 1352	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1479

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in black ink that reads "Jennifer M. Walker".

Jennifer Walker

Operations Manager

Reported: 12/07/2020 09:34

