



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J0K1313

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: BOCES Seaway Adult Ed

Fred Hauck  
 20104 NYS Route 3  
 Watertown, NY 13601

Project / PO Number: N/A  
 Received: 11/06/2020  
 Reported: 11/25/2020

**Analytical Testing Parameters**

<b>Client Sample ID:</b> 11								
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> RF - Client			
<b>Lab Sample ID:</b> J0K1313-01					<b>Collection Date:</b> 10/27/2020 6:45			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1508	LLW

<b>Client Sample ID:</b> 8								
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> RF - Client			
<b>Lab Sample ID:</b> J0K1313-02					<b>Collection Date:</b> 10/27/2020 6:44			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0053	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1513	LLW

<b>Client Sample ID:</b> 9								
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> RF - Client			
<b>Lab Sample ID:</b> J0K1313-03					<b>Collection Date:</b> 10/27/2020 6:43			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0056	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1515	LLW

<b>Client Sample ID:</b> 6								
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> RF - Client			
<b>Lab Sample ID:</b> J0K1313-04					<b>Collection Date:</b> 10/27/2020 6:41			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1517	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1313

<b>Client Sample ID:</b> 2	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0K1313-05		<b>Collection Date:</b> 10/27/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1519	LLW

<b>Client Sample ID:</b> 4	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0K1313-06		<b>Collection Date:</b> 10/27/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0041	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1520	LLW

<b>Client Sample ID:</b> 13	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0K1313-07		<b>Collection Date:</b> 10/27/2020 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1526	LLW

<b>Client Sample ID:</b> 3	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0K1313-08		<b>Collection Date:</b> 10/27/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1528	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1313

<b>Client Sample ID:</b> 5	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0K1313-09		<b>Collection Date:</b> 10/27/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0041	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1530	LLW

<b>Client Sample ID:</b> 10	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0K1313-10		<b>Collection Date:</b> 10/27/2020 6:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0015	0.015 AL	0.0010	mg/L		11/23/20 1143	11/23/20 1532	LLW

<b>Client Sample ID:</b> 1	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0K1313-11		<b>Collection Date:</b> 10/27/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0012	0.015 AL	0.0010	mg/L		11/23/20 1228	11/23/20 1833	LLW

<b>Client Sample ID:</b> 12	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0K1313-12		<b>Collection Date:</b> 10/27/2020 6:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/23/20 1228	11/23/20 1835	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1313

Client Sample ID: 7	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 10/27/2020 6:42
Lab Sample ID: J0K1313-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0044	0.015 AL	0.0010	mg/L		11/23/20 1228	11/23/20 1841	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Sara Lechleitner  
Customer Relationship Coordinator  
Reported: 11/25/2020 15:12

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice  
MNY Workorder #

3421 Beck Drive  
Cortland NY 13045  
Phone: (607) 53-3403 Fax: (607) 53-3415  
NY # 10/95, EPA # NY09035

SL BOLES - Seaway - Adult Ed

**Client Information**

Name: Jeff/LCW Boxes  
Address: 20104 NYS Route 3  
Contact: Health/Safety Dept.  
Phone: 315-779-7000  
Project: Lead Testing  
Quote ID: PO#  
Rush TAT Bus. Days: 2-5 5-7 7-10 Date Req:  
Carbon Copy: Yes  
Email Results: Yes  
Fax Results: Yes

**Analysis Requested**

Plastic  
250 ml  
HINO3

**Receiving Info (Lab Use Only)**

Ice: YES NO  
Cooler: YES NO  
Sample Temp: YES NO  
Cooler Seal: YES NO  
Pickup: YES NO  
Dropoff: C W  
Accepted? YES NO

Container Material  
Container Size (in MI)

Preservative

**Sample Information**

Description/Location  
Date  
Time  
Matrix Type

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
11	8	9	6	2	7	13	3	5	10	7	12									
10/27																				
6:45	6:44	6:43	6:41	6:38	6:39	6:47	6:39	6:40	6:44	6:37	6:46	6:42								
DW																				

**Number of Containers for Analysis Requested**

1																				
---	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

**Comments/Field Data**

JOK1313  
Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
PM: Shannon Weeks

**Print Name and Company**

Linda Shaw

Date/Time  
10/28/20  
10:30 am

**Comments**

1 of 1

11/6/2020 1700

Jennifer Walker

Sampled: Linda Shaw  
Received: Jennifer Walker

Microbac Laboratories, Inc. is not responsible for performance portion of the requested testing or which case we will subcontract the analysis to another accredited laboratory. This document contains information that you have been informed by MNY of the intent to subcontract and are in agreement with this action.